

BIDS AND AWARDS COMMITTEE

19 March 2024

SUPPLEMENTAL BID BULLETIN NO. 24-006

This Supplemental Bid Bulletin No. 24-006 is to amend or modify items in the Bid Documents and in response to the queries raised during the pre-bid conference conducted on 14 March 2024 for "Supply, Delivery and Installation of a Brand New 1-Unit 250kVA, 3Phase, 400V Generator Set - Silent Type with Accessories (including Housing) for the ICC" to wit:

Item/Query	Answers	
Regarding the generator, is it synchronized ready?	It is not synchronized ready. The bidder will provide the synchronization panel and tap it to the existing generator.	
2. Regarding the capacity bank, is it included in the generator set?	Capacity bank should be provided by the bidder which will be placed inside the existing low voltage switchgear. Prior to the installation, a shop drawing should be submitted for approval.	
3. Existing Model No. of control panel	DSE 6110	
4. Warranty period	 Civil Works - 5 years Genset - 1000 hours operation (500 hours/year) or 2-years parts and labor, or whichever comes first. 	
5. "Regarding the SLCC, we have no SLCC in civil works but we have SLCCs in gensets supply and installation?"	SLCC is for both generator set and housing in a single project and shall be at least 50% of the completed project similar in nature.	
6. Request for an As-built Plan.	See attached as-built plans. Please note that actual measurements and site condition must be verified.	

For the guidance and information of all concerned bidders.

Dr. PRIMO G. GARCIA Chair, BAC		
Received by the Bidder:		
	Date:	
Signature over printed name		

0



